

NTPC TAMILNADU ENERGY COMPANY LTD.
(A Joint Venture of NTPC Ltd. & TNEB)
Vallur Thermal Power Project,
Kurvimedu Village, VellivoyalChavadi - PO,
Chennai - 600103

Date:16.09.2022

TENDER ID : 2022_NTECL_127059_1 & Tender Ref No. CS-5156


Tender Title: Repair works of fire water tanks

Clarification No.1 to bid document

Sl.No.	Clause details	Description/ Query raised by the bidder	Clarification by NTECL
1	SECTION-IV, Scope of work, Cl.No.18, Painting works	<ol style="list-style-type: none">1. In NORSOK M501 standard which system we follow for Internal & External Paint.2. What kind of Product for internal & External.3. What kind of RAL you need in internal & External Paint.4. Mention the thickness of welding details.	<ol style="list-style-type: none">1. External painting should be NORSOK M501 system No.7 (Carbon steel in splash zone)2. Product should be satisfied above standard.3. Colour of external and internal tank should be fire red (shade no.5)4. Welding joints is double beaded from internal and external of plates.

All other terms and conditions of tender shall remain unaltered.




(S. Hariprasad)
Sr. Manager (C&M)
NTECL